

Trusted Since 1900

FAX

Pages: This cover + _0

To: Tom Barry Project Manager New Town Corp. 711 S. Columbus Ave. Mount Vernon, NY 10550

FAX: 914-663-2313

Date: April 9, 2009

From: Steve Hubbard

RE: Brick Cleaner Project: P.S/I.S. 276

Tom-

Based on the information provided in the Diedrich technical literature, the 202V Vana-Stop cleaning product would be an acceptable cleaner on our Limestone colored brick, which are identified on your project as bricks M1 and M2.

Please contact me if you have any questions.

Steve Hubbard Distributor Sales Manager 800-477-7137

CC: Larry Kotke, Diedrich Technologies

www.mutuslmaterials.com

605 119th Avenue NE P.O. Box 2009 Bellevue, WA 98009

425.452.2300 Lel 425.454,7732 fax